



Certificate of Analysis

Client:	Lotus at Siam.Co.NZ Limited	Lab No:	2126164	DW MAVPv1
Contact:	Duncan Laing 9 Ernlea Terrace Cashmere Christchurch 8022	Date Received:	18-Feb-2019	
		Date Reported:	19-Feb-2019	
		Quote No:	93770	
		Order No:		
		Client Reference:	Ernlea Terrace	
		Submitted By:	Duncan Laing	

Sample Type: Aqueous

Sample Name:	Lotus Spa 18-Feb-2019 9:00 am	Maximum Acceptable Value	Outside Limit
Lab Number:	2126164.1		
Escherichia coli	MPN / 100mL	< 1	No

The Maximum Acceptable Values (MAV) are taken from the publication 'Drinking-water Standards for New Zealand 2005 (Revised 2008)', Ministry of Health. Copies of this publication are available from:
<http://www.health.govt.nz/publication/drinking-water-standards-new-zealand-2005-revised-2008>

The Maximum Acceptable Values (MAVs) have been defined by the Ministry of Health for parameters of health significance and should not be exceeded. The 'Drinking-water Standards for New Zealand' also contains Guideline Values which are the limits for aesthetic determinands that, if exceeded, may render the water unattractive to consumers. This report compares the results obtained with the Maximum Acceptable Values only.

Under Section 69ZZ (2) of the Health Act (1965), the laboratory is required to report the results of any analysis or test carried out (for the purposes of testing for compliance with the New Zealand Drinking Water Standards 2005 (Revised 2008)) that indicates any non-compliance (transgression) with the Maximum Acceptable Values (MAVs) to the Drinking Water Assessor.

Note that the units g/m³ are the same as mg/L and ppm.

Summary of Methods

The following table(s) gives a brief description of the methods used to conduct the analyses for this job. The detection limits given below are those attainable in a relatively clean matrix. Detection limits may be higher for individual samples should insufficient sample be available, or if the matrix requires that dilutions be performed during analysis. Unless otherwise indicated, analyses were performed at Hill Laboratories, 28 Duke Street, Frankton, Hamilton 3204.

Sample Type: Aqueous

Test	Method Description	Default Detection Limit	Sample No
E.coli Only		1 MPN / 100mL	1
Escherichia coli	MPN count using Colilert (Incubated at 35°C for 24 hours), or Colilert 18 (Incubated at 35°C for 18 hours), Analysed at Hill Laboratories - Microbiology; 101c Waterloo Road, Hornby, Christchurch. APHA 9223 B 23 rd ed. 2017.	1 MPN / 100mL	1

These samples were collected by yourselves (or your agent) and analysed as received at the laboratory.

Samples are held at the laboratory after reporting for a length of time depending on the preservation used and the stability of the analytes being tested. Once the storage period is completed the samples are discarded unless otherwise advised by the client.

This certificate of analysis must not be reproduced, except in full, without the written consent of the signatory.

Padam (Nishan) Subba Grad Dip LT, Post Grad Dip AppSc
Laboratory Technician - Microbiology

