



## Certificate of Analysis

Page 1 of 1

|                 |   |                          |              |       |
|-----------------|---|--------------------------|--------------|-------|
| <b>Client:</b>  | Lotus at Siam.Co.NZ Limited                                       | <b>Lab No:</b>           | 2226336      | DWPV1 |
| <b>Contact:</b> | Duncan Laing<br>9 Ernlea Terrace<br>Cashmere<br>Christchurch 8022 | <b>Date Received:</b>    | 19-Aug-2019  |       |
|                 |   | <b>Date Reported:</b>    | 20-Aug-2019  |       |
|                 |   | <b>Quote No:</b>         | 93770        |       |
|                 |   | <b>Order No:</b>         |              |       |
|                 |   | <b>Client Reference:</b> |              |       |
|                 |   | <b>Submitted By:</b>     | Duncan Laing |       |

### Sample Type: Aqueous

| Sample Name:     | Lotus Spa 19-Aug-2019 9:00 am | Guideline Value | Maximum Acceptable Values (MAV) |
|------------------|-------------------------------|-----------------|---------------------------------|
| Lab Number:      | 2226336.1                     |                 |                                 |
| Escherichia coli | MPN / 100mL                   | < 1             | < 1                             |

**Note:** The Guideline Values and Maximum Acceptable Values (MAV) are taken from the publication 'Drinking-water Standards for New Zealand 2005 (Revised 2018)', Ministry of Health. Copies of this publication are available from <https://www.health.govt.nz/publication/drinking-water-standards-new-zealand-2005-revised-2018>

The Maximum Acceptable Values (MAVs) have been defined by the Ministry of Health for parameters of health significance and should not be exceeded. The Guideline Values are the limits for aesthetic determinands that, if exceeded, may render the water unattractive to consumers.

**Under Section 69ZZ (2) of the Health Act (1965), the laboratory is required to report the results of any analysis or test carried out (for the purposes of testing for compliance with the New Zealand Drinking Water Standards 2005 (Revised 2018)) that indicates any non-compliance (transgression) with the Maximum Acceptable Values (MAVs) to the Drinking Water Assessor.**

Note that the units g/m<sup>3</sup> are the same as mg/L and ppm.

## Summary of Methods

The following table(s) gives a brief description of the methods used to conduct the analyses for this job. The detection limits given below are those attainable in a relatively clean matrix. Detection limits may be higher for individual samples should insufficient sample be available, or if the matrix requires that dilutions be performed during analysis. Unless otherwise indicated, analyses were performed at Hill Laboratories, 28 Duke Street, Frankton, Hamilton 3204.

| Test             | Method Description   | Default Detection Limit | Sample No |
|------------------|--|-------------------------|-----------|
| E.coli Only      |  | 1 MPN / 100mL           | 1         |
| Escherichia coli | MPN count using Colilert (Incubated at 35°C for 24 hours), or Colilert 18 (Incubated at 35°C for 18 hours), Analysed at Hill Laboratories - Microbiology; 101c Waterloo Road, Hornby, Christchurch. APHA 9223 B 23 <sup>rd</sup> ed. 2017. | 1 MPN / 100mL           | 1         |

These samples were collected by yourselves (or your agent) and analysed as received at the laboratory.

Samples are held at the laboratory after reporting for a length of time depending on the preservation used and the stability of the analytes being tested. Once the storage period is completed the samples are discarded unless otherwise advised by the client.

This certificate of analysis must not be reproduced, except in full, without the written consent of the signatory.

Marisa Fonseka BSc Grad Dip LT  
Laboratory Technician - Microbiology



This Laboratory is accredited by International Accreditation New Zealand (IANZ), which represents New Zealand in the International Laboratory Accreditation Cooperation (ILAC). Through the ILAC Mutual Recognition Arrangement (ILAC-MRA) this accreditation is internationally recognised. The tests reported herein have been performed in accordance with the terms of accreditation, with the exception of tests marked \*, which are not accredited.