



Certificate of Analysis

Page 1 of 1

Client:	Lotus at Siam.Co.NZ Limited	Lab No:	2396781	DWPV1
Contact:	Duncan Laing 9 Ernlea Terrace Cashmere Christchurch 8022	Date Received:	06-Jul-2020	
		Date Reported:	07-Jul-2020	
		Quote No:	93770	
		Order No:		
		Client Reference:	Ernlea Terrace	
		Submitted By:	Duncan Laing	

Sample Type: Aqueous

Sample Name:	Lotus Spa 06-Jul-2020 8:40 am	Guideline Value	Maximum Acceptable Values (MAV)
Lab Number:	2396781.1		
Escherichia coli	MPN / 100mL	< 1	< 1

Note: The Guideline Values and Maximum Acceptable Values (MAV) are taken from the publication 'Drinking-water Standards for New Zealand 2005 (Revised 2018)', Ministry of Health. Copies of this publication are available from <https://www.health.govt.nz/publication/drinking-water-standards-new-zealand-2005-revised-2018>

The Maximum Acceptable Values (MAVs) have been defined by the Ministry of Health for parameters of health significance and should not be exceeded. The Guideline Values are the limits for aesthetic determinands that, if exceeded, may render the water unattractive to consumers.

Under Section 69ZZ (2) of the Health Act (1965), the laboratory is required to report the results of any analysis or test carried out (for the purposes of testing for compliance with the New Zealand Drinking Water Standards 2005 (Revised 2018)) that indicates any non-compliance (transgression) with the Maximum Acceptable Values (MAVs) to the Drinking Water Assessor.

Note that the units g/m³ are the same as mg/L and ppm.

Summary of Methods

The following table(s) gives a brief description of the methods used to conduct the analyses for this job. The detection limits given below are those attainable in a relatively simple matrix. Detection limits may be higher for individual samples should insufficient sample be available, or if the matrix requires that dilutions be performed during analysis. A detection limit range indicates the lowest and highest detection limits in the associated suite of analytes. A full listing of compounds and detection limits are available from the laboratory upon request. Unless otherwise indicated, analyses were performed at Hill Laboratories, 28 Duke Street, Frankton, Hamilton 3204.

Test	Method Description	Default Detection Limit	Sample No
E.coli Only		1 MPN / 100mL	1
Escherichia coli	MPN count using Colilert (Incubated at 35°C for 24 hours), or Colilert 18 (Incubated at 35°C for 18 hours), Analysed at Hill Laboratories - Microbiology, 101c Waterloo Road, Hornby, Christchurch. APHA 9223 B 23 rd ed. 2017.	1 MPN / 100mL	1

These samples were collected by yourselves (or your agent) and analysed as received at the laboratory.

Dates of testing are available on request. Please contact the laboratory for more information.

Samples are held at the laboratory after reporting for a length of time based on the stability of the samples and analytes being tested (considering any preservation used), and the storage space available. Once the storage period is completed, the samples are discarded unless otherwise agreed with the customer. Extended storage times may incur additional charges.

This certificate of analysis must not be reproduced, except in full, without the written consent of the signatory.

Marisa Fonseca BSc Grad Dip LT
Team Leader - Microbiology



This Laboratory is accredited by International Accreditation New Zealand (IANZ), which represents New Zealand in the International Laboratory Accreditation Cooperation (ILAC). Through the ILAC Mutual Recognition Arrangement (ILAC-MRA) this accreditation is internationally recognised. The tests reported herein have been performed in accordance with the terms of accreditation, with the exception of tests marked *, which are not accredited.